



ADDENDUM NO. 4

TO THE CONTRACT DOCUMENTS FOR

WELL NO. 6

PROJECT NO. 17022.00

LEEDS, ALABAMA

JANUARY 2018

PREPARED BY:



INSITE
ENGINEERING

InSite Engineering, LLC
5800 FELDSPAR WAY
HOOVER, ALABAMA 35244
PHONE: 205-733-9696
FAX: 205-733-9697

Copyright 2018



This page intentionally left blank.

ADDENDUM NO. 4

OWNER: LEEDS WATER WORKS BOARD
PROJECT: WELL NO. 6
PROJECT NUMBER: 17022.00

The Contractor shall incorporate the following changes into the Contract Documents and include the cost of all changes listed herein in his proposed contract prices. **The Contractor must acknowledge receipt of this Addendum on Page 1 of the Bid Form.** The above referenced Contract Documents are hereby amended as described below:

Changes to Specifications:

None.

Changes to Drawings

A4.1 Sheet MS-1 **MECHANICAL SECTION "A"**: Delete 10" D.I. Butterfly Valve from the Finished Water line. Valve is located next to the Finished Water Air Release Valve.

Other Clarifications

The following questions have been asked during the bid period:

Q1: Are the piping and fittings required to be domestic?

The ductile iron pipe shall be supplied by the Manufacturers outlined within Section 331413 paragraph 2.2.A..

The ductile iron fittings may domestic or import as outlined within Section 331413.

Q2. Is this project a SRF funded project?

No.

Q3. Do Davis Bacon Wage rates apply?

No.

ADDENDUM NO. 4
LEEDS WATER WORKS BOARD
WELL NO. 6
JANUARY 16, 2018
Page 2 of 2

- Q4. At what point is the Contractor responsible for maintenance of the access road? I noticed sever potholes in the gravel driveway well before the “Bag Supply Plant”?

Special care should be taken on all concrete surfaces. Contractor to ensure that any mud, rocks, debris, etc. that has been placed sue to the construction is cleaned daily from concrete area. Contractor is encouraged to photograph all areas necessary to complete the work.

- Q5. Sheet 10 of the drawings shows a 10” FL butterfly valve next to the 10” x 4” Tee on the Finished Water Piping. Sheet 8 does not show the 10” FL butterfly valve. Please confirm if a valve is to be installed. Is it to be electric actuated or manual?

The 10” butterfly valve has been deleted from the project.

The above changes shall be incorporated into the Contract Documents for the above referenced project. The bidder must acknowledge receipt of this Addendum on Page 1 of the Bid Form.

Additional Attachments

None.

END OF ADDENDUM NO. 4
