



WALTER SCHOEL ENGINEERING COMPANY, INC.
1001 22nd Street South • Birmingham, Alabama 35205
P 205-323-6166 • F 205-328-2252 • schoel.com

MEMORANDUM

TO: Bidders

FROM: Andrew Phillips

DATE: November 21, 2018

SUBJECT: Addendum No. 2

Please verify that you have received Addendum No. 2 and taken the proposed modifications into account. The following revisions are part of Addendum No. 2 and should be incorporated into the construction documents;

Plan Revisions – Industrial Water Main

1. Cover Sheet- Revised to reflect revisions to Sheer Index
2. Sheet C-204- Revised to reflect New IW2 alignment
3. Sheets C-402-C408- Revised to reflect New IW2 alignment
4. Sheet C-208- Line IW3, the size of the tee has to revised to a 10"X10"X10"
5. Sheet C-302- Revised to reflect Alternate No.1
6. Sheet PP-112- Existing Control Panel is identified at CUP 1
7. Sheet PP-122- Sheet was added to show the Existing Control Panel at CUP 3
8. Sheet PP-131- Existing Control Panel is identified at CUP 5

Project Manual Revisions

1. Added Control Panels Section
2. Added SCADA Systems